

Condenser Units Mounted Indoors

****Applies to all condenser units except VRF equipment****

Outdoor units can be mounted indoors provided the following conditions are met:

1. That it violates no State, Local, or Federal Code requirements.
2. That the discharge of the outdoor unit does not cause the area that the unit is placed in to rise above or below the operating range of the outdoor unit.
3. An independent drain pan is mounted below the outdoor unit to catch any moisture that the unit produces and routed the water to an acceptable drain receptacle. In climates where temperatures do not fall below 32°F (0°C) equipment drain plugs and drain outlet can be used.
(Heatpumps only)
4. All distances required by the install manual are followed.