





## SF - 036 REV2

DATE: July 11, 2019

TO: All Service and Parts Managers SUBJECT: Low Voltage Board Connectors

The communicating controls in Goodman's Furnaces, Split Condensers, Heat Pumps and Air-Handlers are shipped with the required Phoenix connectors needed for connecting the low voltage wiring to these units. However, we understand these connectors can from time to time get misplaced preventing you from completing the installation; therefore, we have made these connectors available through service parts. Please refer to the following list for part numbers when ordering connectors:

Furnace and Air-Handler 9 pin connector: #F043067300S

Split Condenser or Heat Pump 7 pin connector: #F043067500S or 0130M00485

Communicating mode 4 pin connector: # F043067900S or 0130D00002

ComfortBridge™ Control Platform Furnace 6 pin Connector: # F043068000S









## July 2019 Revision:

As announced in PMN #C-PC-SP-1733, the introduction of the ComfortBridge<sup>™</sup> technology has minimized the need for the 7-pin connector with communicating condensing units. Beginning August 1, 2019, the 7-pin connector will be removed from the condensing units listed below. The 7-pin connector (Part numbers # F043067500S or 0130M00485) will continue to be available through service parts for 24 VAC, non-communicating applications.

Amana	Goodman
ASXC160241	GSXC160241
ASXC160361	GSXC160361
ASXC160481	GSXC160481
ASXC160601	GSXC160601
ASXC180241	GSXC180241
ASXC180361	GSXC180361
ASXC180481	GSXC180481
ASXC180601	GSXC180601

T: 888-593-9988 | F: 713-316-5541

Produced by Goodman Business Unit Technical Services | 19001 Kermier Road | Waller, TX 77484